



深圳腾凯特种机电有限公司
SHENZHEN TENKAI GROUP LIMITED

SPECIFICATION FOR APPROVAL

规格承认书

To: 2610054566

产品型号 Par No.: DA1504L33Y

类别 Category: ☒ Fan ☐ Blower ☐ Centrifugal

认证 Certification: ☒ CE ☐ ROHS ☐ UL ☐ TUV

编号 Spec No: DA1504L33Y-A261008 版次 Version: 01

样品数 Quantity: 2PCS 日期 Date: 2026-10-22



Company Stamp	CUSTOMER APPROVAL Stamp
	
制作: 周珍莲	承认:
复核: 蔡继国	核准:
核准:	日期:

电话(TEL): 86-0755-23126453 传真(FAX): 86-0755-23129135

邮箱(MAIL): sales@tenkai-group.com

网址(WEB): [Http://www.tkfan.com](http://www.tkfan.com)

地址(ADD): 深圳市龙华区观澜格澜 9 路金雄达科技园 C 栋 5 楼



LEAD WIRE
UL 36AWG OR EQUIVALENT
PIN1: RED WIRE---(+)
PIN2: BLACK WIRE---(-)

UNIT: $\frac{\text{mm}}{(\text{INCH})}$

Mark 记号	REASON 变更原因	PROJECTION		单位 UNIT mm		深圳市腾凯特种机电有限公司 SHEN ZHEN TENKAI GROUP LIMITED			
				比例 SCALE 1: 1		型号 Model NO.	DA1504L33Y	图号 Drawing NO. DA1504L33Y-A261008	
		公差 TOL	LINEAR (0,50] (50,100] (100,+∞]	.X ±0.10 ±0.20 ±0.30	.XX ±0.05 ±0.10 ±0.15	ANGULAR X. X.X	±0.5° ±0.1°	描述 Description DC BRUSHLESS FAN	日期 Date 2026. 10. 22
			It is prohibited to duplicate this document without explicit authorization or to hand it over to others for use.						日期 Date 2026. 10. 22
									日期 Date
						检查 Check	蔡继国	日期 Date 2026. 10. 22	材料 Material
						批准 Approved		日期 Date	表面 Finish
								页数 Page 1/1	版次 Rev A0

規格參數

SPECIFICATION

Model 型号:			
Item 项目	Unit 单位	Specification 參數	Condition 條件
Dimension 尺寸	Mm 毫米	15X15X4	LxWxThickness 长宽高
Bearing System 轴承类型	----	Hydraulic Bearing	----
Rated Voltage 额定电压	VDC	3.3	----
Operating Voltage Range 操作电压范围	VDC	2~6	At 25℃
Start-up Voltage 启动电压	VDC	≤2	At 25℃
Rated Current 额定电流	Amp 安培	0.022A±10%	At Rated 在额定电压下
Lock Rotor Current 锁定电流	Amp 安培	0.00	Locked 锁死
Rated Power 额定功耗	Watt 瓦特	0.073±10%	At Rated 在额定电压下
Rated Speed 额定转速	RPM 圈/分钟	8000RPM±15%	At Rated Voltage 30℃
Air Flow 风量	CFM	0.0124±10%	In Free Air 无风阻条件
Static Air Pressure 静压	mmH ₂ O		When Air Flow=0
Noise Level 噪音	dBA	22.10±10%	At Rated Speed 额定转速
Polarity protection 反向保护	--	Reverse protection	Yes
Other Spec.	Tachometer Output 转速反馈	NO	
	Soft-restart function 软启动	NO	
	Lock Protection 锁定保护	Yes	
	Lock Rotor Alarm 锁定报警	NO	
	PWM Control 速度控制	NO	
	Thermal Control 过热保护	NO	
	Over voltage protection 过压保护	NO	
	Over current protection 过流保护	NO	
	fixed constant speed Function 恒速功能	NO	
Connection Lead Type 连接方式	Lead Wire 导线型号	70mm 36AWG	See Page 2 见图纸
	Connector 端子	JST 02SUR-36L	See Page 2 见图纸
Life Expectancy 预期寿命	Hours 小时	30000hrs	At 25℃ 在 25℃条件下
Net Weight 净重	g 克	1.0g	1PCS
备注 Note			

絕緣耐壓 Dielectric Strength	5Ma Max./導線与外框間測量，500VAC/min 5Ma Max./Measured between lead wire(+)and frame at 500VAC/min
極數 Number of Pole	2 極 2 Poles
EMC	Pass
運轉溫/濕度範圍 Operating temp. Range	溫度/temperature: -40℃~+80℃ 濕度/Humidity: 35%~85%RH
絕緣阻抗 Insulation Resistance	10MΩ /裸線与外框間測量，500VDC/min 10MΩ/between unshackled wire and frame at 500VDC/min
耐濕性 Humidity	電器規格依據 MIL-STD 202F Method 103B 濕度: 95%RH, 溫度: 40±2℃ According to MIL-STD 202F Method 103B Humidity: 95%RH,Temp.: 40±2℃
熱衝擊 Thermal Shock	電器規格依據 MIL-STD 202F Method 107D According to MIL-STD 202F Method 107D
絕緣階段 Insulation Shock	UL: A 種 UL: Class A
包裝耐振試驗 Packing Vibration Test	包裝后，XYZ 施 1.1KG 測試 30 分鐘無損壞 Load Vibration test for 30min,No serious damage

SHENZHEN TENKAI GROUP

MODEL NO.

DA1504L33Y

MTBF REPORT

STARTED DATE: 2025.5.16

FINISHED DATE: 2025.10.20

TEST CONDITIONTEST

(1) VOLTAGE:3.3VDC
(2) TEMPERATURE:
75℃

ITEM

SPECIFICATION

TEST SAMPLES

20

OPERATION
VOLTAGE

3.3VDC

TEST HRS/EA

2,200

CUPPENT
DPAIN

0.022A±10%

TOTAL TEST HRS

44,000

SPEED

8000RPM±15%

FAILURE Q'TY

0

ACOUSTICAL
NOISE

CONFIDENCE
LEVEL

90%

MTBF

30,574hours

FAILURE DEFINITION

ITEM

CHECK POINT AT THE HOURS

Over

(1) CURRENT:= 10%/-30%of
Original value

TEST DURATION(HRS)

250

500

1k

1.5k

2k

2.2
k

ACCUMULATED FAILURE Q'TY

0

0

0

0

0

0

SURVIVAL Q'TY

20

20

20

20

20

20

Over

(2) RPM: 30%/-15%of
Original value

ACCUMULATED FAILURE RATIO

0%

0%

0%

0%

0%

0%

FAILNO.TEST
TIME(HRS)SURVIVAL Q'TY

ACCUMULATED FAIL RATIO
DESCRIPTION

(3) NOISE Over±10% of
LEVEL: origin

TEST RESULT:

1. FORMULA OF FIGURING OUT ACCELERATION
FACTOR:

Tu: Required Temp (25℃)

Ta: Experiment

$AF = 2^{\wedge}[(Ta-Tu)]$

Temp.(75℃)

$= 2^{\wedge}[(75-25)/10]$

$= 32$

$MTBF = [ACTUAL TEST TIME * SAMPLE$

$Q'TY] * AF] / TR / SAMPLE Q'TY$

$MTBF = [(2200 * 20) * 32] / 2.3026 / 20 = 30, 574 HOURS$

2. CONFIDENCE LEVEL:

ACCORDING TO GEM
TABLE90%

ZERO FAILURE TR=2.302
6

APPROVED BY: BOPING GONG

CHECKED BY: SHU LIN XIE

TESTED BY: JUN ZHANG

风扇特性曲线风量风压测试报告

The Report of Fan Performance P-Q Curve Test

1.产品特性依照 AMCA-210 标准在双箱里包括风量与风压的测试。
The performance including air flow and air pressure measured in Double Chamber is measured according to AMCA210-92 standard。

测试编号(No.): 7259 测试日期(Date) : 2026/10/22

2.测试数据:

序号 No.	项目 Item	规格 Specification	单位 Unit
1	测试电压 Test Voltage	3.3V	VDC
2	转速 Speed	8000	RPM
3	大气压力 Barometric Pressure	761.5	mmHg
4	相对湿度 Relative Humidity	52	%
5	最大风量(零静压时)Max.Air Flow(At Zero Static Pressure)	0.0124	CFM
6	最大风压（零风量时）Max. Air Pressure(At Zero Air Flow)		mmH ₂ O



3.P-Q 数据及曲线 P-Q Data and Curve

序号	mmAq	CFM	A	Watt	RPM
1					
2					
3					
4					
5					
6					
7					
8					

噪音测试报告

The Report of Acoustic Noise Test

报告编号 Report No.TN1511309

样品名称 Sample Name	Brushless Fan / Blower
测试条件 Test Condition	测试方法 Test Method
1.温度 Temperature: 31 °C 2.湿度 Humidity: 75 %RH	1.测试位置 Test Position : 180° 2.测试距离 Test Distance:1.0M From the fan intake 3.背景噪音 Background Noise: 16.1dB(A) 4.测试依照标准 ISO3745 执行 This test executes according to ISO3745 standard
测试设备 Test Equipment: 声望 VA-Lab2 二通道噪声频谱分析仪 BSWA VA-Lab2 double channels noise Spectrum Analyzer	
测试结果 Test Result: Leq:22.1dB(A); 测试距离 Test distance: 1 meter	
倍频段频谱图 Octave-Band(1m)	
	
测试结果 Test Result: Leq:16.1dB(A); 背景噪音 Background Noise	
	

※本报告未经许可严禁擅自更改其中内容 Do not change the content of this report without written permission of authority;
※一般情况, 委托检验结果仅对所检验样品有效 Generally, commission test is responsible for the tested samples only;
※报告无主检、审核人签字无效 The test report is invalid without the signatures of Author and Reviewer.

实物图

The pictures

